






ECONOMICS OF SUSTAINABILITY?...

Not Everything in Life that can be counted 'really Counts' Immeasurable Dimensions of sustainability Ar. Shirish Beri



Year	Unit (kWh) Rate	MD (kVA) Rate	Cumulative Rate
FY 2012-13	6.00	150	7.03
FY 2013-14	7.09	200	8.19
FY 2014-15	8.02	200	9.11
% Change	34%	33%	30%
1000000		A PARTY OF THE PAR	\$2550 CONTRACTOR 15.30





Rectifications to improve IAQ & Comfort

Rectification of Duct Leakages





- INVST. : Rs. 5 Lacs
- SAVINGS: Rs. 2.6 Lacs PA
- PAYBACK : 23 Months


Rectification of toilet exhaust fans






- INVST. : Rs. 1 Lac
- SAVINGS : Rs. 36,000 PA
- PAYBACK : 2.7 Years


Project : L&T NB2, Mumbai Gold Rated IGBC EBO&M




















Platinum R



Water Pumping System- An Efficient Pumping Solution



✓ Monthly Energy Consumption Reduction : 44%

✓ Water Pumping Efficiency Improvement(kWh/KL) : 12 to 4

↑ Payback (months) : 30

Heat Pump

➤ PNG Consumption : 1.8 Lac SCM/Ann.

➤ Proposed system : 15 KLD

➤ PNG saving/day : 95 SCM

➤ Cost of PNG/SCM : Rs. 35/SCM

> Energy consumption : 182 kWh/day

of heat pump/day

➤ Working day/year : 350 days

> Payback : 2.4 Years





	SCORE CARD ENERGY & WATER						
Energy Cons.	Units	2009-10	2010-11	2011-12	2012-13	2013-14	
Energy	kWh Units	48,703	45,406	42,928	44,257	43,655	
	% diff	Base Year	-7%	-12%	-9%	-10%	
Max.	kVA	197	164	158	164	136	
Demand	% diff	Base Year	-17%	-20%	-17%	-31%	
Water	Units	2009-10	2010-11	2011-12	2012-13	2013-14	
вмс	kL	229	118	113	134	111	
5	% diff	Base Year	-49%	-51%	-41%	-52%	

100		ECO	NOMIC	CS OF E	FFICEN	CY C	ASE ST	UDY				
	'	Week 1		Week 2		Week 3		Week 4				
HVAC SYS	WEEK	WEEK END	% CHG	WEEK DAYS	WEEK END	% CHG	WEEK DAYS	WEEK END	, ,	WEEK DAYS	WEEK END	% CHG
Chiller	10,965		38%		4,818	43%	9,792	3,880		10,288		40%
Run Hours	44	24	53%	44	24	53%	39	36	92%	42	24	56%
Pri. Pump	931	482	52%	919	467	51%	791	701	89%	857	476	56%
Sec. Pump	2,709	2,632	97%	2,643	2,519	95%	2,597	2,551	98%	2,637	2,411	91%
CT Fan	820	290	35%	761	264	35%	760	507	67%	732	376	51%
Cond. Pump	1,263	649	51%	1,251	544	43%	1,022	950	93%	1,230	721	59%
		SPECIF	IC POV	VER CO	NSUMI	PTION	(KW/T	R) OF C	HILLER			
	0.75	0.71	1	0.74	9	.69	0.7	3	0.74		■kW	/TR
10750	0.65	Week-1	W	Sales -	Wee	k 3	Week	4	Week 5		NO 12 TO	2.78
					VA.	14	Veek	1.16			1111	

HVAC System	Units	Weekdays	Weekends	% Change
		Before		
Run Hours	hr	44	21	46%
Chiller	kWh	11,490	4,081	36%
Primary Pump	kWh	932	539	58%
Secondary pump	kWh	2,838	2,585	91%
Condenser Pump	kWh	702	233	33%
CT Fan	kWh	1,394	684	49%
		After		
Chiller	kWh	43	22	51%
Run Hours	hr	9,681	3,557	37%
Primary Pump	kWh	887	458	52%
Secondary pump	kWh	2,062	1,519	74%
Condenser Pump	kWh	542	173	32%
CT Fan	kWh	1,449	867	60%
	A	NNUAL SAVINGS		
Energy		kWh	288,576	
Monetary	,	INR	2,020,032	

GENERIC CHALLENGES.....

- Stakeholder Awareness
- **❖** Project Management : Motivation
- Energy / Water Accountability at System Level
- ❖ Selection & Sourcing of 'Appropriate' Technology / material
- Capacity Building : Skilled Workforce
- Integration of Systems with IBMS
- Documentation

It's not about the points to get a Building certified...

The points are not the point
The points are not sustainable.
Are we missing the actual point?

Courtesy: Ar. Karan Grover

