



# Implementation of energy efficient technologies/measures in existing buildings




## Gaps and Barriers






## Comfort monitoring


### Visual Comfort







Spaces	Illumination level	
	Operating levels	NBC Recommended levels
Office (cabins)	510	300-500-750
Toilets	170	100-150-200
Cafeteria	230	150-200-300
circulation areas	125	50-100-150
Meeting rooms	515	300-500-750

### Thermal Comfort










## Baseline development and adjustment- Weather dependent system

CDW in (deg F)	Chiller Loading (%) & Efficiency (kW/TR)									
	100	90	80	70	60	50	40	30	20	15
70	0.426	0.404	0.388	0.378	0.374	0.382	0.4	0.441	0.5	0.576
75	0.472	0.451	0.438	0.43	0.433	0.44	0.464	0.496	0.578	0.658
80	0.52	0.502	0.492	0.49	0.496	0.507	0.525	0.57	0.661	0.746
85	0.576	0.562	0.549	0.552	0.554	0.576	0.597	0.648	0.75	0.85
89	0.624	0.609	0.604	0.605	0.613	0.627	0.653	0.707	0.817	0.924

## Financial Mechanisms



## TERI-UTC Centre of Excellence on energy efficient buildings in India

---

- ▶ [TERI -UTC CoE Brochure.pdf](#)




---

## Case Study



## Space cooling and heating systems in India





## Environmental Issues in off-grid regions

- **Burning of twigs for heating**
- **Deforestation**
- **Air Pollution (formation of carbon layer in atmosphere)**




▶









Case Study-Installation of Geothermal based heat pump at Science Centre, Itanagar



teri

## Site for Geothermal based Heat Pump Installation

---

Science  
Center,  
Arunachal  
Pradesh



teri

## Cooling and heating requirement

---

Cooling load


5 TR

Heating load

7 TR



teri



### Heat Pump Specifications- Water (Geo) source Variable Refrigerant Flow

Make	Samsung		
Type	DVM S WATER		
Model Name	AM080FXWANR/EU		
Power Supply	Φ, #, V, Hz	3,4,380-415,50/60	
Mode	-	HEAT RECOVERY	
Performance	HP	HP	8.00
	Capacity (Nominal)	TR	6.37
Power	Power Input (Nominal)	Cooling 1)	3.84
		Heating 2)	4.12
	Current Input (Nominal)	Cooling 1)	6.20
		Heating 2)	6.60
	MFA		20.00
COP	Nominal Cooling 1)	-	5.83
	Nominal Heating 2)	-	6.12
Compressor	Type	-	SSC Scroll x 1
	Type	-	PHE (Plate Heat Exchanger)
Condenser	Water Flow Rate	USGPM	21.0
	Max. Pressure	MPa	1.96
Refrigerant	Type	-	R410A
	Control		EEV - Electronic Expansion Valve
External Dimension	Net Weight	kg	160.0
	Net Dimensions (WxHxD)	mm	770 x 1,000 x 545
Operating Temp. Range (Water)	Cooling	°C	10.0 ~ 45.0
	Heating	°C	10.0 ~ 45.0

## System Comparison with Conventional Heat Pump (Energy Simulation Results)

### Cooling mode

Energy consumption with conventional heat pump	:	5486 kWh/yr
Energy consumption with geothermal heat pump	:	3924 kWh/yr
<b>% Saving</b>	:	<b>29%</b>

### Heating mode

Energy consumption with conventional heat pump	:	2004 kWh/yr
Energy consumption with geothermal heat pump	:	1382 kWh/yr
<b>% Saving</b>	:	<b>31%</b>



## Digging of trench for geo-exchange



Digging  
through JCB  
machine



Digging  
through manual  
labour



## Preparation of slinky loops

Slinky were prepared manually with the help of a die



## Laying of slinky in the trench



teri

## Refilling of the trench



After setting the slinky ends, the trench was refilled and levelled with JCB machine



teri

## Connection of slinky ends to inlet/outlet manifolds with appropriate fittings



Pipe ends were connected to the inlet and outlet manifolds through compression fittings




teri

## Testing of Geo-exchange System



The testing results at a flow rate of 4.1 USGPM for one of the slinky



The average heat rejection per slinky was calculated to be around 1 TR.



## Commissioning of Indoor Units (IDUs) with Refrigerant and Drain Piping



4 No's Indoor Units of 1.6 TR capacity each were installed in the Auditorium. Leak test of drain pipes ; and Vacuum test of refrigerant tubing were also carried out



## Commissioning of Outdoor Unit (ODU)



Installation and Testing of Y-strainer, Flow Switch, Air-Vent valve, Pressure & Temperature gauges, Pressure Tank and Water Circulation Pump with ODU.



Satisfactory operation of all the systems was ensured.



## Commissioning of Remote Monitoring System (RMS)

DMS-  
Data Management  
Server

Internet Modem



PIM-  
Power Interface  
Module



RMS  
Interface





## Radiant floor cooling/heating system



## Energy and cost analysis-Radiant cooling

### **Geothermal system**

Energy savings	30-40%
Costing	1.2 Lakh Rs/TR
Payback	3 years



## Geothermal system



Geothermal system	
Peak Building Load	75 TR
Average Building load	40 TR
Load catered by Geothermal vertical system	20 TR



## Resource and cost analysis-Geothermal

### **Geothermal system**

Energy savings	10-15%
Water savings	14L/TR
Costing	40000 Rs/TR



